

EV.X

series/serisi

LIGHTING FIXTURES

Aydınlatma Armatürleri

INSTALLATION / KULLANIM

Hazardous Areas, Zone: 1/2 (Gases) - 21/22 (Dusts)
Tehlikeli Sahalar, Bölge: 1/2 (Gazlar) - 21/22 (Toz)

CLASSIFICATION/ SINIFLANDIRMA

Group II - Category 2G/2D
Grup II - Kategori 2G/2D



EV . X

Armatür



UYGULAMA

EV.X serisi akkor ya da Kompakt floresan ampullü (tasarruflu) aydınlatma armatürleri Grup II tehlikeli açık ya da kapalı alanlarda kullanılmaktadır.

APPLICATION

EV.X series incandescent or compact fluorescent lighting fixtures are used in Group II hazardous areas at in door or out door services.

EV .X Series Lighting Fixtures

ATEX 2014/34/EU

Execution/Sertifika Kodu	II 2G Ex d IIB T* Gb -20°C ≤ Tamb ≤ +40°C
Installation/Kullanım Sahası	Zone 1/2 - Zone 21/22
Watt Range/ Watt Aralığı	T* = T4 (250W-400W) T* = T5 (100W-200W)
Certificate Ref./Sertifika No	TSE 19ATEX0133 X
Rules of Compl./ Uyum Kuralları	EN 60079-0:2012+A11:2013, EN 60079-1:2014



Mechanical Characteristics		Electrical Characteristics	
Gaskets	Nbr Rubber	Internal Wiring	High Temperature Resistant Silicon Cable
Cable Entry	3/4" Threaded	Screws	External Stainless Steel

Photometric diagrams

